

## NOTICE OF DEVIATION

### Section 1 (To Be Completed By The Person Discovering The Deviation)

Study Number: TX210

Source Document(s): ☒ Protocol ☐ SOP (List SOP Number(s)):

Describe the Requirement (give section numbers for SOPs):

#### Animal Husbandry

Animals will be housed and cared for in accordance with the Institute of Laboratory Animal Research (ILAR), Commission on Life Sciences, NRC document entitled, *Guide for the Care and Use of Laboratory Animals* (1996).

The animals will be housed in a vivarium with controlled lighting (12 hours of darkness, from 6:00 p.m. to 6:00 a.m. +/- 30 minutes, Eastern Standard Time, except on the days converting to and from daylight savings time), temperature (18-26°C, or 64.4-78.8°F), relative humidity (RH, 30-70%), and airflow (greater than 10 air changes per hour). Seven-day, continuous chart-wheel recordings will be kept of RH and temperature [*SOP EQP064 or EQP019*]. In addition, room airflow and light cycles will be monitored continuously, and data recorded every 30 minutes to a computer file via the automated facility data collection system [*SOP DAT025*]. Brief excursions of airflow, temperature, and relative humidity lasting less than 1 hour and less than 10% from the upper or lower boundaries of the stated conditions, will not be reported as protocol deviations.

Describe the Deviation: Date of Occurrence: 4/22/08 During LIMS check, it was noted that there was no recording at 2:00 PM. Facilities Maintenance reported that the network was down from ~2:00PM to 2:20 PM. During investigation of the of the problem, the network connection was re-established.

Documented By: CAB

Date: 4/23/08

### Section 2 (To Be Completed By The Study Director)

Describe the Corrective Action(s) To Be Taken In Response To The Deviation:

No action can be taken.

Assessment Of The Deviation's Impact Upon The Outcome Of The Study:

None.

Study Director's Signature: gs

Date: 4-23-08

DAT024.001.010904